

EGOLF RECOMMENDATION 007-2016

Subject of Agreement	Measurements of deflection during leakage measurement at ambient temperature
Related test standard	EN 1366-8
Date of issue	October 2016
Reference original query	EGOLF TC2, N784, Helpdesk 2015-13
Previous publication number (if applicable)	
Keywords (max. 20)	deflection, leakage, ambient, temperature, sealing, opening

Problem

The standard EN 1366-8 states that the deflection measurements at ambient temperatures should be made after the sealing over the openings are removed.

There will be no under-pressure in the duct when the sealing is off, and therefore no deflection of the duct.

It is believed more informative to perform the deflection measurements when the sealing is on because the duct will have the required under pressure at this time.

Recommendation

Exchange EN 1366-8 §10.2.5 and EN 1366-8 §10.2.4 taking the measurement of deflection before the sealing over the openings are removed.