

EGOLF AGREEMENT 007-2016

Subject of Agreement	Testing flooring tiles also available as full size
Related test standard	EN ISO 9239-1
Date of issue	2005
Reference original query	TC1 N276 Helpdesk 2005-01
Previous publication number (if applicable)	ER 31
Keywords (max. 20)	flooring, flooring tiles, joints, mounting

Problem

Flooring products can be available as flooring tiles in different dimensions, and also as wall-to-wall products. If the product is tested as a full-scale specimen, are the results also valid for flooring tiles of different dimensions?

EN ISO 9239-1 states *If the specimen consists of tiles, it shall be mounted in such a way that a joint is situated 250 mm from the zero point.*

The words "if" and "specimen" (not "product") would indicate that the joints are optional.

Agreement

- Test results of floorings tested without any cross joint are also valid for tile made out of that flooring.
- If in the end use application additional materials shall be used in the joints, the tiles together with this additional material in the joint have to be tested separately ("testing the system").